


TYPICAL WIRING DIAGRAM



NOTE:  
1. 3-4 Main switch/closes on temperature rise  
2. C compressor

DESIGNED BY	S. B. Chen	18.3.13	Pressure Thermostat	Customer: VETRA
CHECKED BY	W. G. Tan	18.3.15		
INSPECTED BY	G. H. Chan	18.3.15		
APPROVED BY	L. H. Sim	18.3.16		
Reviser Number	SIGN	DATE		
Customer code: 077B1106				
Tongbao code: KPF28V				
Design Mark	Number	Weight(kg)	Proportion	
A			1:1	
WIRING DIAGRAM			FOSHAN TONGBAO HUATONG CONTROLLER CO.,LTD.	

Operating Temperature (mmHg)	SIGNAL IN(°C)	Warm	Normal	Cold
	CUT IN(°C)			
Operating Temperature (760mmHg)	CUT OUT(°C)			
	DIFF(°C)			
The second testing temp is taken as an accurate value.				
Electrical Ratings	Rated Volts (V)	Power Factor (Cosφ)	AC	
			230	120
Rated Amperes (A)	Non-inductive	Full Load	3-4	3-4
			0.5-6	1-10
Inductive Load	Full Load	0.75	0.5-6	1-10
		0.45	0.5-36	1-40
Insulation Resistance	More than 100MΩ with a DC500V megger			
Dielectric Strength	AC 1500V for one minute			
Kind of charge	Gas(R290)			
Conditions of Operating Temp.	TS>TB TS: Temperature Around the Main Frame TB: Temperature around the Sensing Element			
Response Characteristic of Sensing Element	Temp. change rate: ≤ 1°C/min			
Max. Temperature	Around the Main Frame: 70°C Around the Sensing Element: 80°C			
Life of Contact	200,000 Cycles			
Rotating Moment of Adjusting shaft	COLD — WARMER 0.02-0.35N.m WARMER — OFF less than 0.6N.m			
Remarks:	1. The length of capillary immersed in the testing medium shall reach more than 150 mm. 2. The temperature characteristic is under a 760mmHg of atmosphere at 25°C 3. Thermostat shown in COLD position 4. The material requests according to the RoHS.			